

HAZARDOUS CHEMICALS REGISTER

Instructions

Complete, keep and maintain this *Hazardous Chemicals Register* for all existing and new chemicals used by staff. This register should be readily accessible by all staff and contractors who use or who may be affected or exposed to any of the hazardous chemicals listed herein.

All hazardous chemicals must have a current safety data sheet (SDS) and an accompanying risk assessment that is no more than five years old. The SDS must state whether the product is hazardous and, in case of dangerous goods, provide the proper shipping name, class label, subsidiary risk, and packing group details. Copies of the SDSs must be attached to this register.

Site		255 Elizabeth Street, Sydney NSW 2000			
Date of Register		12 th January 2024 (based on inspection on 11 th December 2023)			
Assessor	Name	Ben McCann	Position Title	Senior Associate – Property Risk	
	Company	Tetra Tech Coffey	Client Contact Name	Adrian Everingham	

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Level B6, Parking Bay 137/138									
Diesel	Fuel	Level B6, Parking Bay 137 / 138 Underground Tank	1 x 25,000L	25,000L	Yes	3	4	Jan 2027	-
Level B6, Sprinkler Pump Room									
Diesel	Fuel	Level B6, Sprinkler Pump Room	1 x 120L	120L	Yes	3	4	Jan 2027	-
Lead Acid Batteries	Battery	Level B6, Sprinkler Pump Room	4 units	4 units	Yes	8	3	Not Available	Provide a current SDS in a readily accessible location.

HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
B3, Cleaners Cage									
Diversey Glance NA J-Fill	Cleaning Product	B3, Cleaners Cage	3 x 2.5L	7.5L	Yes	-	-	March 2024	-
Diversey Taski Clean Air J-Fill	Cleaning Product	B3, Cleaners Cage	1 x 2.5L	2.5L	Yes	-	-	Dec 2023	-
Diversey Stride Citrus HC J-Fill	Cleaning Product	B3, Cleaners Cage	2 x 2.5L	5L	Yes	-	-	Dec 2027	-
Desert Washroom Cleaner	Cleaning Product	B3, Cleaners Cage	1 x 5L	5L	Yes	-	-	Aug 2023	-
Whiteley Viraclean	Cleaning Product	B3, Cleaners Cage	1 x 5L	5L	No	-	-	April 2025	-
Whiteley Mr Steel	Cleaning Product	B3, Cleaners Cage	1 x 5L	5L	No	-	-	Aug 2026	-
Cleanmax Bleach 4%	Cleaning Product	B3, Cleaners Cage	6 x 5L	30L	Yes	-	-	Nov 2026	-
Northfork All Purpose Cleaner	Cleaning Product	B3, Cleaners Cage	1 x 5L	5L	Yes	-	-	Not Available	Provide a current SDS in a readily accessible location.
Northfork Disinfectant	Cleaning Product	B3, Cleaners Cage	1 x 5L	5L	No	-	-	Not Available	-
Diversey Taski Cream R7	Cleaning Product	B3, Cleaners Cage	2 x 5L	10L	Yes	-	-	Not Available	Provide a current SDS in a readily accessible location.
Citrus Resources Orange Solv GP	Cleaning Product	B3, Cleaners Cage	2 x 5L 1 x 0.5L	10.5L	Yes	3	3	Sept 2026	-
Diversey Glance	Cleaning Product	B3, Cleaners Cage	3 x 5L	15L	No	-	-	Not Available	-
Diversey Clean Air	Cleaning Product	B3, Cleaners Cage	2 x 5L	10L	Yes	-	-	Dec 2027	-
Diversey Go Getter	Cleaning Product	B3, Cleaners Cage	1 x 5L	5L	Yes	-	-	Nov 2023	Replace outdated SDS with current version.

HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Diversey Earthon Laundry Powder	Cleaning Product	B3, Cleaners Cage	1 x 7.5kg	7.5kg	Yes	-	-	Dec 2027	-
B1, Cleaners Cupboard									
Diversey Taski Clean Air J-Fill	Cleaning Product	B1, Cleaners Cupboard	1 x 2.5L	2.5L	Yes	-	-	Dec 2027	-
Diversey Crew J-Fill	Cleaning Product	B1, Cleaners Cupboard	1 x 2.5L	2.5L	Yes	-	-	March 2025	-
Diversey Stride Citrus HC J-Fill	Cleaning Product	B1, Cleaners Cupboard	1 x 2.5L	2.5L	Yes	-	-	Dec 2027	-
Diversey Glance NA J-Fill	Cleaning Product	B1, Cleaners Cupboard	1 x 2.5L	2.5L	Yes	-	-	Jan 2024	-
Level 5, Generator Room									
Diesel	Fuel	Level 5, Generator Room	1 x ~400L	~400L	Yes	3	4	Jan 2027	-
Hi-Tec Batteries	Battery	Level 5, Generator Room	2 units	2 units	Yes	8	3	Not Available	Provide a current SDS in a readily accessible location.
Hard working Nifti	Cleaning Product	Level 5, Generator Room	1 x 0.5L	0.5L	Yes	-	-	Sept 2026	-
Valvoline All Fleet Plus E900, 15W-40	Cleaning Product	Level 5, Generator Room	1 x 20L	20L	No	-	-	March 2023	-
PG Plus, Premium Engine Coolant	Cleaning Product	Level 5, Generator Room	1 x 20L	20L	Yes	-	-	March 2024	-

HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Shock Treatment Heavy Duty Biodegradable Degreaser	Cleaning Product	Level 5, Generator Room	1 x 5L	5L	Yes	8	3	Not Available	Provide a current SDS in a readily accessible location.
Level 16, Chiller Room									
R-134A	Refrigerant	Level 16, Chiller Room	3 x 273kg	819kg	Yes	2.2	N/A	Jan 2025	-
Hydrochem Hydro 428	Water treatment	Level 16, Chiller Room	1 x 15L	15L	Yes	-	-	May 2021	Replace outdated SDS with current version
Level 16, Cooling Tower Area									
Hydrochem Hydro 360	Water treatment	Level 16, Cooling Tower Area	1 x 15L	15L	Yes	8	3	March 2026	-
Hydrochem Hydro 426	Water treatment	Level 16, Cooling Tower Area	1 x 15L	15L	Yes	-	-	Not Available	Provide a current SDS in a readily accessible location.
Hydrochem Hydro 428	Water treatment	Level 16, Cooling Tower Area, dosing pot	1 x 15L	15L	Yes	-	-	Dec 2026	-
Hydrochem Hydro 256	Water treatment	Level 16, Cooling Tower Area	1 x 15L 1 x 20L	35L	Yes	8	3	Feb 2028	-
Hydrochem Hydro 260X	Water treatment	Level 16, Cooling Tower Area	1 x 50L	50L	Yes	8	3	Oct 2027	-
Unlabelled container	Unknown	Level 16, Cooling Tower Area	1 x 15L	15L	Unknown	Unknown	Unknown	Not Available	Provide a current SDS in a readily accessible location.

HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Remco Lead Acid Batteries	Battery	Level 16, Cooling Tower Area	4 units	4 units	Yes	8	3	Not Available	Provide a current SDS in a readily accessible location.
Diesel	Fuel	Level 16, Cooling Tower Area	2 x ~100L	~200L	Yes	3	4	Jan 2027	-