

## HAZARDOUS CHEMICALS REGISTER

### Instructions

Complete, keep and maintain this *Hazardous Chemicals Register* for all existing and new chemicals used by staff. This register should be readily accessible by all staff and contractors who use or who may be affected or exposed to any of the hazardous chemicals listed herein.

All hazardous chemicals must have a current safety data sheet (SDS) and an accompanying risk assessment that is no more than five years old. The SDS must state whether the product is hazardous and, in case of dangerous goods, provide the proper shipping name, class label, subsidiary risk, and packing group details. Copies of the SDSs must be attached to this register.

Site		31 Market Steet, Sydney NSW 2000			
Date of Register		29 <sup>th</sup> August 2024. Inspected on 12 <sup>th</sup> August 2024.			
Assessor	Name	Ben McCann	Position Title	Senior Associate – Property Risk	
	Company	Tetra Tech Coffey	Client Contact Name	Richard Eusebio	

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Level 37 Hydrant Pump Room									
12V Batteries	Battery	Hydrant Pump Room	3 x units	3 units	Yes	8	N/A	Not Available	Provide current SDS in a readily accessible location
Diesel	Fuel	Hydrant Pump Room	20L x 2	~100L	Yes	3	4	October 2025	-
		Hydrant Pump Room, in tank	~60L						
Valvoline Advanced OEM 05 Coolant	Coolant	Hydrant Pump Room	5L x 1	5L	Yes	-	-	Not Available	Provide current SDS in a readily accessible location

## HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Level 37 External Cooling Tower Area									
Hydrochem Hydro 360	Water Treatment	Level 37 Cooling Tower Area	15L x 1	15L	Yes	8	3	March 2026	-
Hydrochem Hydro 256	Water Treatment	Level 37 Cooling Tower Area	15L x 2	30L	Yes	8	3	Feb 2028	-
Hydrochem Hydro 260	Water Treatment	Level 37 Cooling Tower Area	15L x 2	30L	Yes	8	3	April 2026	-
Hydrochem Hydro375	Water Treatment	Level 37 Cooling Tower Area	15kg x 1	45kg	Yes	5.1 (8)	2	June 2026	Store at least 3m away from Class 8 chemicals.
		Level 37 Cooling Tower Area, dosing pots	15kg x 2						
Level 37 Telecom Room									
12V Batteries	Battery	Telecom Room	16 x units	16 units	Yes	8	N/A	Not Available	Provide current SDS in a readily accessible location
Level 37 Generator Room									
Diesel	Fuel	Generator Room, Fuel Tank	400L x 1	400L	Yes	3	4	Not Available	Provide current SDS in a readily accessible location
Shell Rimula Oil	Oil	Generator Room	20L x 1	20L	-	-	-	Not Available	Provide current SDS in a readily accessible location
12V Batteries	Battery	Generator Room	2 x units	2 units	Yes	8	N/A	Not Available	Provide current SDS in a readily accessible location
Level 36 External Plant Area									
Diesel	Fuel	External Plant Area, Fuel Tank	~800L x 1	~800L	Yes	3	4	Not Available	Provide current SDS in a readily accessible location

## HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Level 36 Chiller Room									
R1234ze Refrigerant	Refrigerant	Chiller Room, Chiller 4	269kg x 1	269kg	Yes	2.2	N/A	Not Available	Provide current SDS in a readily accessible location
R134a Refrigerant	Refrigerant	Chiller Room, Chillers 1, 2 and 3	385kg x 3	1,155kg	Yes	2.2	N/A	Not Available	Provide current SDS in a readily accessible location
Level 36 Calorifier Room									
Hydrochem Hydro 428	Water Treatment	Calorifier Room, dosing pots	15L x 2	30L	Yes	-	-	May 2021	Replace expired SDS with current version
Level LG Cleaners Store Room									
Elite Graffiti Remover	Cleaner	Cleaners Store Room	1L x 1	1L	Yes	3	3	Not Available	Provide current SDS in a readily accessible location
Chemi Tab Refresher Tabs	Cleaner	Cleaners Store Room	4kg x 1	4kg	Yes	-	-	Not Available	Provide current SDS in a readily accessible location
Kleenex Luxury Foam Hand Sanitiser	Cleaner	Cleaners Store Room	1L x 45	45L	Yes	3	2	Not Available	Provide current SDS in a readily accessible location
Diversey Go Getter	Cleaner	Cleaners Store Room	1L x 1	1L	Yes	-	-	Not Available	Provide current SDS in a readily accessible location
Level LG Sprinkler Pump Room									
12V Batteries	Battery	Sprinkler Pump Room	7 x units	7 units	Yes	8	N/A	Not Available	Provide current SDS in a readily accessible location
Diesel	Fuel	Sprinkler Pump Room	50L x 2 80L x 1 20L x 3	240L	Yes	3	4	October 2025	-
Level B1 Cleaners Storeroom									
Amano Pioneer Eclipse Neutral All Purpose Cleaner	Cleaner	Level B2 Cleaners Storeroom	10L x 2	20L	-	-	-	April 2026	-

## HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Whiteley Tile Plus	Cleaner	Level B2 Cleaners Storeroom	5L x 2	10L	Yes	8	2	<b>Not Available</b>	Provide current SDS in a readily accessible location
Elite White Oil	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	-	-	-	Jan 2027	-
Elite King Bleach	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	Yes	8	3	Jan 2027	-
Elite Uriclean	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	Yes	-	-	<b>Not Available</b>	Provide current SDS in a readily accessible location
Elite Eucalyptus Spray & Wipe	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	-	-	-	Jan 2026	-
Elite Multiklean	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	Yes	-	-	Jan 2027	-
Elite Ultra Fresh	Cleaner	Level B2 Cleaners Storeroom	20L x 2	40L	-	-	-	Jan 2027	-
Elite Red Flash Detergent	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	Yes	8	2	Jan 2026	-
Elite Clearclean Glass & Mirror Cleaner	Cleaner	Level B2 Cleaners Storeroom	20L x 3	60L	-	-	-	Jan 2026	-
Elite Disinfectant Lemon	Cleaner	Level B2 Cleaners Storeroom	20L x 2	40L	-	-	-	Jan 2026	-
Desert Washroom	Cleaner	Level B2 Cleaners Storeroom	5L x 3	15L	Yes	-	-	<b>Not Available</b>	Provide current SDS in a readily accessible location
Desert Microbial Waterless Urinal Cubes	Cleaner	Level B2 Cleaners Storeroom	1kg x 7	7kg	Yes	-	-	<b>Not Available</b>	Provide current SDS in a readily accessible location

## HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Level B1 Power and Battery Room									
Kwik Gas	LPG	Comms Room	8.5kg x 1	8.5kg	Yes	2.1	N/A	Not Available	Provide current SDS in a readily accessible location
Level B2 Storeroom N									
Lonkoon Hand Sanitiser	Cleaner	On Shelving	0.5L x ~700	~350L	Yes	3	2	Not Available	Provide current SDS in a readily accessible location Install Placarding on Door.