

## HAZARDOUS CHEMICALS REGISTER

### Instructions

Complete, keep and maintain this *Hazardous Chemicals Register* for all existing and new chemicals used by staff. This register should be readily accessible by all staff and contractors who use or who may be affected or exposed to any of the hazardous chemicals listed herein.

All hazardous chemicals must have a current safety data sheet (SDS) and an accompanying risk assessment that is no more than five years old. The SDS must state whether the product is hazardous and, in case of dangerous goods, provide the proper shipping name, class label, subsidiary risk, and packing group details. Copies of the SDSs must be attached to this register.

Site		34-38 Anzac Avenue, Smeaton Grange NSW			
Date of Register		30 <sup>th</sup> August 2024. Inspected on 14 <sup>th</sup> August 2024			
Assessor	Name	Ben McCann	Position Title	Senior Associate – Property Risk	
	Company	Tetra Tech Coffey	Client Contact Name	Jino Velasco	

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Sprinkler Pump Room									
Diesel	Fuel	Sprinkler Pump Room	80L x 2 20L x 4	240L	Yes	3	4	Dec 2025	-
Aus Cell 12V Batteries	Battery	B1 Sprinkler Pump Room	8 units	8 units	Yes	8	N/A	Jan 2026	-

## HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
External Area, Adjacent Unit 5 Entrance									
LPG	Fuel	External Area, Adjacent Unit 5 Entrance	~7,000kg x 1	~7000kg	Yes	2.1	N/A	Not Available	Provide current SDS in a readily accessible location