

Mirvac Real Estate Pty Ltd

Hazardous Chemicals Assessment

34-38 Anzac Avenue, Smeaton Grange NSW

30 August 2024

Project Ref: 754-SYDEN364426



HAZARDOUS CHEMICALS ASSESSMENT

Prepared for
Mirvac Real Estate Pty Ltd

Prepared by
Tetra Tech Coffey Pty Ltd
Level 20, Tower B, 799 Pacific Highway
Chatswood NSW 2067 Australia
t: +61 2 9406 1000 f: +61 2 9406 1002
ABN: 55 139 460 521

Quality information

Revision history

Revision	Description	Date	Originator	Reviewer	Approver
R01	Final	30/08/2024	Ben McCann	Aaron Holmes	Aaron Holmes

Distribution

Report Status	No. of copies	Format	Distributed to	Date
R01 Final	1	PDF	Mirvac	30/08/2024

30 August 2024

754-SYDEN364426

CONTENTS

Executive summary	iii
Assessment Findings	iii
Recommendations	iii
1. Introduction	1
1.1 Site Description	1
1.2 Assessment Objectives	1
2. Methodology	1
2.1 Inaccessible Areas	1
3. Duties of the PCBU	2
4. Background information	2
4.1 Definitions	2
4.2 Hazard Classes	3
4.3 Hazard Category	3
5. Assessment Findings	3
5.1 Summary of Hazardous Chemicals Identified on Site	3
5.2 Observations	4
6. Recommended Actions	4
6.1 High Priority (action within 1 month)	5
6.2 Medium Priority (action within 3 months)	5
6.3 Low Priority (action within 6 months)	5
7. References	5
8. Limitations	6
Appendix A: Photographs	7
Appendix B: Hazardous Chemicals Register	9

EXECUTIVE SUMMARY

Tetra Tech Coffey Pty Ltd (Tetra Tech) was commissioned by Mirvac Real Estate Pty Ltd (the client) to conduct a Hazardous Chemicals Assessment (assessment) of the industrial estate, located at 34-38 Anzac Avenue, Smeaton Grange NSW (the site). Ben McCann conducted the assessment on 14th August 2024.

Assessment Findings

Summary of Hazardous Chemicals Identified on Site

The following table presents a summary of the approximate total volumes of hazardous chemicals stored on site by hazard class. It also details whether placarding and/or manifests are required for any hazardous chemicals stored in bulk at the site. Refer to **Appendix B** for full hazardous chemicals register.

Hazard Class	Approximate Quantity Stored on Site	Placarding Required	Manifest Required
Class 2.1 – Flammable gases	7,000kg	Yes	Yes
Class 2.1 – Aerosols	-	-	-
Class 2.2 – Non-flammable, non-toxic gases	-	-	-
Class 3 – Flammable liquids	-	-	-
Class 3 (Category 4) – Combustible liquids	240L	-	-
Class 5.1 – Oxidising substances	-	-	-
Class 5.2 – Organic peroxides	-	-	-
Class 6.1 – Toxic substances	-	-	-
Class 8 – Corrosive substances	8 Batteries	-	-
Class 9 – Miscellaneous	-	-	-
Unknown and/or Unclassified	-	-	-

Observations

The following observations were made at the time of the assessment (refer to **Appendix A** for a photographic supplement):

- Quantities of LPG stored on site exceeded the threshold level for placarding. A Class 2.1 location placard was available on the LPG tank, however a HAZCHEM outer warning placard was not available at the vehicle entrance to the site.

- Quantities of LPG on site exceeded the threshold level for a manifest, however no manifest or emergency plan was available for review.
- All inspected hazardous chemicals observed on site appeared to be appropriately labelled and stored in sealed containers.
- The diesel containers in the Sprinkler Pump Room were not stored within secondary containment.
- No incompatible hazardous chemicals were observed on site.
- Hazardous chemical storage areas appeared to be appropriately ventilated.
- A spill kit was available in the Sprinkler Pump Room.
- Appropriate fire safety measures (dry chemical fire extinguisher) appeared to be available in the Sprinkler Pump Room.
- The bulk LPG tank appeared to be appropriately protected from vehicle impact.
- Hazardous chemical storage areas were secured from unauthorised access (e.g. within locked rooms).
- A copy of the hazardous chemicals register was not available within any of the chemical storage areas at the time of the assessment.
- Current safety Data Sheets (SDSs) were available for the diesel and batteries in the Sprinkler Pump Room, however an SDS for the bulk LPG was not available on site.

Recommendations

The following recommended actions (and the associated indicative recommended timeframes) are provided based on the findings and observations presented above:

High Priority (action within 1 month)

- No high priority recommendations.

Medium Priority (action within 3 months)

- Install an appropriate outer warning HAZCHEM placard at the vehicle entrance to the site to warn emergency services of the bulk LPG stored at the site.
- Ensure a current manifest and emergency plan is available for the bulk LPG stored on site.

Low Priority (action within 6 months)

- Ensure a copy of the hazardous chemicals register is made available in the Sprinkler Pump Room and is readily accessible to workers.
- Ensure the diesel containers in the Sprinkler Pump Room are provided with adequate secondary containment.
- Ensure that a current printed copy of the LPG SDS is made available somewhere on site (e.g. within the Sprinkler Pump Room), as well as within a central storage hub.
- Require as a condition of service contract, that all contractors engaged at the site provide a register of the chemicals they intend to use/store on site as well as a current SDS.
- Ensure all staff and contractors working within chemical storage areas at the site are provided with appropriate information, instruction, and training to ensure they are able to work safely in these areas. It is recommended that this be managed within the site induction.
- Implement a periodic hazardous chemicals assessment at the site to ensure the requirements are being maintained and the register remains current. It is recommended that such a review is performed at least annually, or when significant changes are made to the hazardous chemicals used/stored on site.

- A copy of this report and register should be made available to any staff and contractors working within the relevant areas at the site.

1. INTRODUCTION

Tetra Tech Coffey Pty Ltd (Tetra Tech) was commissioned by Mirvac Real Estate Pty Ltd (the client) to conduct a Hazardous Chemicals Assessment (assessment) of the industrial estate, located at 34-38 Anzac Avenue, Smeaton Grange NSW (the site). Ben McCann conducted the assessment on 14th August 2024.

1.1 Site Description

The site consisted of 2 industrial buildings (approximate area of 130,000m²). The buildings were occupied at the time of the assessment. Key chemical storage areas included the Sprinkler Pump Room and external LPG tank area.

1.2 Assessment Objectives

The objectives of this assessment were as follows:

- Conduct a visual inspection of all common areas (tenanted areas were not included) at the site.
- Liaise with relevant site personnel and collect data on the location, type, quantities, use and function of the hazardous chemicals stores on site.
- Assess the risks associated with the storage of hazardous chemicals on site.
- Evaluate the effectiveness of risk control measures implemented at the site to manage hazardous chemical storage.
- Provide recommended actions to rectify any identified non-conformances and minimise the identified risks.
- Prepare an up-to-date hazardous chemicals register for the site.

2. METHODOLOGY

The assessment consisted of an on-site visual inspection to identify and assess, so far as reasonably practicable, the presence, location and condition of hazardous chemicals at, on, and associated with the site. Areas were visually inspected for containers and storage vessels that may contain any potentially hazardous chemicals. Visual assessment of the type of all hazardous chemicals identified was conducted with product details recorded including estimated volumes, and whether the contents were labelled or indicated through signage. All chemical storage areas were accessed, where reasonably practicable, and where no access was available, locations were recorded within Section 2.1 of this report. The assessment was carried out methodically, systematically and diligently to make sure all relevant areas of the premises were inspected.

Hazardous properties of each hazardous chemical stored on site were collated from the Safety Data Sheets (SDS). Where the SDS was unavailable, generic hazardous properties for the class of hazardous chemicals were used. For each hazardous property identified, an assessment was made to determine whether this hazardous property resulted in a risk to occupants of the chemical storage area or any adjacent areas.

Data collected during the assessment was compared to the legislative documents and standards listed in Section 7.

2.1 Inaccessible Areas

The following areas were not accessible at the time of the assessment. The presence/absence of hazardous chemicals in these areas cannot be confirmed until further investigation can confirm or refute the presence.

- Occupied areas/tenancies.

- Areas not specified as chemical storage areas.

3. DUTIES OF THE PCBU

A Person Conducting a Business or Undertaking (PCBU) of a premises where hazardous chemicals are stored and handled has a duty to identify the hazards associated with the hazardous chemicals and control the risks arising from their storage and handling. The following duties must also be carried out by the site PCBU:

- Provide appropriate consultation, training, induction and supervision to all workers who are required to work within hazardous chemical storage areas.
- Prepare a register of all hazardous chemicals stored or used at the site.
- Obtain current SDSs for all hazardous chemicals stored or used on site.
- Prepare a manifest of any hazardous chemicals stored in bulk quantities above the relevant threshold limits.
- Display appropriate placards for hazardous chemicals stored in bulk quantities above the relevant threshold limits.
- Ensure hazardous chemical storage areas are appropriately ventilated.
- Ensure hazardous chemical containers and pipework are protected from damage.
- Ensure all hazardous chemical containers and pipework are appropriately labelled.
- Ensure that incompatible hazardous chemicals are appropriately segregated.
- Ensure appropriate spill containment provisions are provided for all hazardous chemicals.
- Ensure suitable fire safety measures are available and appropriately maintained.
- Provide health monitoring to workers who may be exposed to hazardous chemicals in levels exceeding the relevant exposure standards.

Note: The above duties are specified in Part 7.1 of the *Work Health and Safety Regulation 2017 (NSW)*. The PCBU of this site is considered to be the Property Manager.

4. BACKGROUND INFORMATION

4.1 Definitions

Definitions of key terms used in this assessment report and within the hazardous chemicals register are provided below:

- Hazard Class – The nature of a physical, health or environmental hazard under the Globally Harmonised System of Classification and Labelling of Chemicals (GHS). Refer to Section 4.2 for further details.
- Hazard Category – A division of criteria within a hazard class in the GHS. Refer to Section 4.3 for further details.
- Hazardous Chemical – A substance, mixture or article that satisfies the criteria for a hazard class in the GHS, as defined in the *Work Health and Safety Regulation 2017 (NSW)*.
- Manifest – A summary of the key information about specific dangerous goods stored at a site, intended to be provided to emergency services in the event of an emergency. Only required for hazardous chemicals stored in large quantities over the threshold limits detailed in the *Work Health and Safety Regulation 2017 (NSW)*.

- Placard – Signage intended to provide a clear visual warning to emergency services that hazardous chemicals are stored at the site. They include outer warning placards, to be installed at the vehicle entrances to the site, and location placards, to be installed on or adjacent to each container or storage area. Only required for hazardous chemicals stored in large quantities over the threshold limits detailed in the *Work Health and Safety Regulation 2017 (NSW)*.

4.2 Hazard Classes

Classes of relevant dangerous goods are listed below:

- Class 2 – Gases.
 - Division 2.1 – Flammable gases.
 - Division 2.2 – Non-flammable, non-toxic gases.
 - Division 2.3 – Toxic gases.
- Class 3 – Flammable liquids.
- Class 5 – Oxidising substances and organic peroxides.
 - Division 5.1 – Oxidizing substances.
 - Division 5.2 – Organic peroxides.
- Class 6 – Acute Toxicity.
 - Division 6.1 – Acute Toxicity.
- Class 8 – Corrosive substances.

Note: It is possible for substances to display more than one characteristic, therefore these substances may fall under more than one hazard class. In such circumstances the substance will have a primary hazard class and a subsidiary class. Subsidiary classes are displayed in brackets in the Hazard Class column of the Hazardous Chemicals Register.

4.3 Hazard Category

To further assist with the identification of hazardous chemicals and their particular hazards, hazard classes are assigned with a hazard category. This represents the level of danger to persons exposed to the hazardous chemical. Hazard categories include the following:

- 1 – Great danger.
- 2 – Medium danger.
- 3 – Minor danger.

5. ASSESSMENT FINDINGS

The assessment findings are detailed in the following sections. Refer to **Appendix A** for a photographic supplement and **Appendix B** for the full Hazardous Chemicals Register.

5.1 Summary of Hazardous Chemicals Identified on Site

The following table presents a summary of the approximate total volumes of hazardous chemicals stored on site by hazard class. It also details whether placarding and/or manifests are required for any hazardous chemicals stored in bulk at the site. Refer to **Appendix B** for full hazardous chemicals register.

Hazard Class	Approximate Quantity Stored on Site	Placarding Required	Manifest Required
Class 2.1 – Flammable gases	7,000kg	Yes	Yes

Hazard Class	Approximate Quantity Stored on Site	Placarding Required	Manifest Required
Class 2.1 – Aerosols	-	-	-
Class 2.2 – Non-flammable, non-toxic gases	-	-	-
Class 3 – Flammable liquids	-	-	-
Class 3 (Category 4) – Combustible liquids	240L	-	-
Class 5.1 – Oxidising substances	-	-	-
Class 5.2 – Organic peroxides	-	-	-
Class 6.1 – Toxic substances	-	-	-
Class 8 – Corrosive substances	8 Batteries	-	-
Class 9 – Miscellaneous	-	-	-
Unknown and/or Unclassified	-	-	-

5.2 Observations

The following observations were made at the time of the assessment (refer to **Appendix A** for a photographic supplement):

- Quantities of LPG stored on site exceeded the threshold level for placarding. A Class 2.1 location placard was available on the LPG tank, however a HAZCHEM outer warning placard was not available at the vehicle entrance to the site.
- Quantities of LPG on site exceeded the threshold level for a manifest, however no manifest or emergency plan was available for review.
- All inspected hazardous chemicals observed on site appeared to be appropriately labelled and stored in sealed containers.
- The diesel containers in the Sprinkler Pump Room were not stored within secondary containment.
- No incompatible hazardous chemicals were observed on site.
- Hazardous chemical storage areas appeared to be appropriately ventilated.
- A spill kit was available in the Sprinkler Pump Room.
- Appropriate fire safety measures (dry chemical fire extinguisher) appeared to be available in the Sprinkler Pump Room.
- The bulk LPG tank appeared to be appropriately protected from vehicle impact.
- Hazardous chemical storage areas were secured from unauthorised access (e.g. within locked rooms).
- A copy of the hazardous chemicals register was not available within any of the chemical storage areas at the time of the assessment.

- Current safety Data Sheets (SDSs) were available for the diesel and batteries in the Sprinkler Pump Room, however an SDS for the bulk LPG was not available on site.

6. RECOMMENDED ACTIONS

The following recommended actions (and the associated indicative recommended timeframes) are provided based on the findings and observations presented above:

6.1 High Priority (action within 1 month)

- No high priority recommendations.

6.2 Medium Priority (action within 3 months)

- Install an appropriate outer warning HAZCHEM placard at the vehicle entrance to the site to warn emergency services of the bulk LPG stored at the site.
- Ensure a current manifest and emergency plan is available for the bulk LPG stored on site.

6.3 Low Priority (action within 6 months)

- Ensure a copy of the hazardous chemicals register is made available in the Sprinkler Pump Room and is readily accessible to workers.
- Ensure the diesel containers in the Sprinkler Pump Room are provided with adequate secondary containment.
- Ensure that a current printed copy of the LPG SDS is made available somewhere on site (e.g. within the Sprinkler Pump Room), as well as within a central storage hub.
- Require as a condition of service contract, that all contractors engaged at the site provide a register of the chemicals they intend to use/store on site as well as a current SDS.
- Ensure all staff and contractors working within chemical storage areas at the site are provided with appropriate information, instruction, and training to ensure they are able to work safely in these areas. It is recommended that this be managed within the site induction.
- Implement a periodic hazardous chemicals assessment at the site to ensure the requirements are being maintained and the register remains current. It is recommended that such a review is performed at least annually, or when significant changes are made to the hazardous chemicals used/stored on site.
- A copy of this report and register should be made available to any staff and contractors working within the relevant areas at the site.

7. REFERENCES

- Work Health and Safety Act 2011 (NSW).
- Work Health and Safety Regulation 2017 (NSW).
- Code of Practice: Managing Risks of Hazardous Chemicals in the Workplace, 2019 (NSW).
- Australian Standard 1940:2017 'The Storage and Handling of Flammable and Combustible Liquids'.
- Australian Standard 1596:2014 'The Storage and Handling of LP Gas'.
- Australian Standard 3833:2007 'The Storage and Handling of Mixed Classes of Dangerous Goods in Packages and Intermediate Bulk Containers'.

8. LIMITATIONS

This report and the associated services performed by Tetra Tech are in accordance with the scope of services set out in the contract between Tetra Tech and the Client. The scope of services was defined by the requests of the Client, by the time and budgetary constraints imposed by the Client, and by the availability of access to the site.

Tetra Tech derived the data in this report primarily from visual inspections, examination of available records, and interviews with individuals with relevant information about the site. In preparing this report, Tetra Tech has relied upon, and presumed accurate, certain information (or absence thereof) provided by government authorities, the Client and others identified herein. Except as otherwise stated in the report, Tetra Tech has not attempted to verify the accuracy or completeness of any such information.

No warranty, undertaking, or guarantee, whether expressed or implied, is made with respect to the data reported or to the findings, observations, and recommendations expressed in this report. Furthermore, such data, findings, observations, and recommendations are based solely upon existence at the time of the assessment. The passage of time, manifestation of latent conditions or impacts of future events (e.g. changes in legislation, scientific knowledge, land uses, etc.) may require further investigation at the site with subsequent data analysis and re-evaluation of the findings, observations, and recommendations expressed in this report.

This report has been prepared on behalf of and for the exclusive use of the Client, and is subject to and issued in connection with the provisions of the agreement between Tetra Tech and the Client. Tetra Tech accepts no liability or responsibility whatsoever and expressly disclaims any responsibility for or in respect of any use of or reliance upon this report by any third party or parties. It is the responsibility of the Client to accept if the Client so chooses any recommendations contained within and implement them in an appropriate, suitable and timely manner.

APPENDIX A: PHOTOGRAPHS

Hazardous Chemicals Assessment



Photo 01. Bulk LPG tank with Class 2.1 location placard.



Photo 02. No HAZCHEM outer warning placard at vehicle entrance to site.




Photo 03. Diesel containers stored without secondary containment in Sprinkler Pump Room.




Photo 04. Spill kit and fire extinguisher in Sprinkler Pump Room.

APPENDIX B: HAZARDOUS CHEMICALS REGISTER

HAZARDOUS CHEMICALS REGISTER

Instructions

Complete, keep and maintain this *Hazardous Chemicals Register* for all existing and new chemicals used by staff. This register should be readily accessible by all staff and contractors who use or who may be affected or exposed to any of the hazardous chemicals listed herein.

All hazardous chemicals must have a current safety data sheet (SDS) and an accompanying risk assessment that is no more than five years old. The SDS must state whether the product is hazardous and, in case of dangerous goods, provide the proper shipping name, class label, subsidiary risk, and packing group details. Copies of the SDSs must be attached to this register.

Site		31 Market Steet, Sydney NSW 2000			
Date of Register		29 th August 2024. Inspected on 12 th August 2024.			
Assessor	Name	Ben McCann	Position Title	Senior Associate – Property Risk	
	Company	Tetra Tech Coffey	Client Contact Name	Richard Eusebio	

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Level 37 Hydrant Pump Room									
12V Batteries	Battery	Hydrant Pump Room	3 x units	3 units	Yes	8	N/A	Not Available	Provide current SDS in a readily accessible location
Diesel	Fuel	Hydrant Pump Room	20L x 2	~100L	Yes	3	4	October 2025	-
		Hydrant Pump Room, in tank	~60L						
Valvoline Advanced OEM 05 Coolant	Coolant	Hydrant Pump Room	5L x 1	5L	Yes	-	-	Not Available	Provide current SDS in a readily accessible location

HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Level 37 External Cooling Tower Area									
Hydrochem Hydro 360	Water Treatment	Level 37 Cooling Tower Area	15L x 1	15L	Yes	8	3	March 2026	-
Hydrochem Hydro 256	Water Treatment	Level 37 Cooling Tower Area	15L x 2	30L	Yes	8	3	Feb 2028	-
Hydrochem Hydro 260	Water Treatment	Level 37 Cooling Tower Area	15L x 2	30L	Yes	8	3	April 2026	-
Hydrochem Hydro375	Water Treatment	Level 37 Cooling Tower Area	15kg x 1	45kg	Yes	5.1 (8)	2	June 2026	Store at least 3m away from Class 8 chemicals.
		Level 37 Cooling Tower Area, dosing pots	15kg x 2						
Level 37 Telecom Room									
12V Batteries	Battery	Telecom Room	16 x units	16 units	Yes	8	N/A	Not Available	Provide current SDS in a readily accessible location
Level 37 Generator Room									
Diesel	Fuel	Generator Room, Fuel Tank	400L x 1	400L	Yes	3	4	Not Available	Provide current SDS in a readily accessible location
Shell Rimula Oil	Oil	Generator Room	20L x 1	20L	-	-	-	Not Available	Provide current SDS in a readily accessible location
12V Batteries	Battery	Generator Room	2 x units	2 units	Yes	8	N/A	Not Available	Provide current SDS in a readily accessible location
Level 36 External Plant Area									
Diesel	Fuel	External Plant Area, Fuel Tank	~800L x 1	~800L	Yes	3	4	Not Available	Provide current SDS in a readily accessible location

HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Level 36 Chiller Room									
R1234ze Refrigerant	Refrigerant	Chiller Room, Chiller 4	269kg x 1	269kg	Yes	2.2	N/A	Not Available	Provide current SDS in a readily accessible location
R134a Refrigerant	Refrigerant	Chiller Room, Chillers 1, 2 and 3	385kg x 3	1,155kg	Yes	2.2	N/A	Not Available	Provide current SDS in a readily accessible location
Level 36 Calorifier Room									
Hydrochem Hydro 428	Water Treatment	Calorifier Room, dosing pots	15L x 2	30L	Yes	-	-	May 2021	Replace expired SDS with current version
Level LG Cleaners Store Room									
Elite Graffiti Remover	Cleaner	Cleaners Store Room	1L x 1	1L	Yes	3	3	Not Available	Provide current SDS in a readily accessible location
Chemi Tab Refresher Tabs	Cleaner	Cleaners Store Room	4kg x 1	4kg	Yes	-	-	Not Available	Provide current SDS in a readily accessible location
Kleenex Luxury Foam Hand Sanitiser	Cleaner	Cleaners Store Room	1L x 45	45L	Yes	3	2	Not Available	Provide current SDS in a readily accessible location
Diversey Go Getter	Cleaner	Cleaners Store Room	1L x 1	1L	Yes	-	-	Not Available	Provide current SDS in a readily accessible location
Level LG Sprinkler Pump Room									
12V Batteries	Battery	Sprinkler Pump Room	7 x units	7 units	Yes	8	N/A	Not Available	Provide current SDS in a readily accessible location
Diesel	Fuel	Sprinkler Pump Room	50L x 2 80L x 1 20L x 3	240L	Yes	3	4	October 2025	-
Level B1 Cleaners Storeroom									
Amano Pioneer Eclipse Neutral All Purpose Cleaner	Cleaner	Level B2 Cleaners Storeroom	10L x 2	20L	-	-	-	April 2026	-

HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Whiteley Tile Plus	Cleaner	Level B2 Cleaners Storeroom	5L x 2	10L	Yes	8	2	Not Available	Provide current SDS in a readily accessible location
Elite White Oil	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	-	-	-	Jan 2027	-
Elite King Bleach	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	Yes	8	3	Jan 2027	-
Elite Uriclean	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	Yes	-	-	Not Available	Provide current SDS in a readily accessible location
Elite Eucalyptus Spray & Wipe	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	-	-	-	Jan 2026	-
Elite Multiklean	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	Yes	-	-	Jan 2027	-
Elite Ultra Fresh	Cleaner	Level B2 Cleaners Storeroom	20L x 2	40L	-	-	-	Jan 2027	-
Elite Red Flash Detergent	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	Yes	8	2	Jan 2026	-
Elite Clearclean Glass & Mirror Cleaner	Cleaner	Level B2 Cleaners Storeroom	20L x 3	60L	-	-	-	Jan 2026	-
Elite Disinfectant Lemon	Cleaner	Level B2 Cleaners Storeroom	20L x 2	40L	-	-	-	Jan 2026	-
Desert Washroom	Cleaner	Level B2 Cleaners Storeroom	5L x 3	15L	Yes	-	-	Not Available	Provide current SDS in a readily accessible location
Desert Microbial Waterless Urinal Cubes	Cleaner	Level B2 Cleaners Storeroom	1kg x 7	7kg	Yes	-	-	Not Available	Provide current SDS in a readily accessible location

HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Level B1 Power and Battery Room									
Kwik Gas	LPG	Comms Room	8.5kg x 1	8.5kg	Yes	2.1	N/A	Not Available	Provide current SDS in a readily accessible location
Level B2 Storeroom N									
Lonkoon Hand Sanitiser	Cleaner	On Shelving	0.5L x ~700	~350L	Yes	3	2	Not Available	Provide current SDS in a readily accessible location Install Placarding on Door.