

HAZARDOUS CHEMICALS REGISTER

Instructions

Complete, keep and maintain this *Hazardous Chemicals Register* for all existing and new chemicals used by staff. This register should be readily accessible by all staff and contractors who use or who may be affected or exposed to any of the hazardous chemicals listed herein.

All hazardous chemicals must have a current safety data sheet (SDS) and an accompanying risk assessment that is no more than five years old. The SDS must state whether the product is hazardous and, in case of dangerous goods, provide the proper shipping name, class label, subsidiary risk, and packing group details. Copies of the SDSs must be attached to this register.

Site		36 Gow Street, Padstow NSW			
Date of Register		2 nd September 2024. Inspected on 15 th August 2024			
Assessor	Name	Ben McCann	Position Title	Senior Associate – Property Risk	
	Company	Tetra Tech Coffey	Client Contact Name	Jino Velasco	

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Sprinkler Pump Room									
Unlabelled Containers Presumed Diesel	Fuel	Sprinkler Pump Room	~200L x 2	~400L	Yes	3	4	Not Available	Confirm status and label container. Provide current SDS in a readily accessible location
12V Batteries	Battery	Sprinkler Pump Room	3 units	3 units	Yes	8	N/A	Not Available	Provide current SDS in a readily accessible location

HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Electrical Switch Room, Adjacent Sprinkler Pump Room									
Unlabelled Containers Presumed Diesel	Fuel	Electrical Switch Room, Adjacent Sprinkler Pump Room	20L x 3	60L	Yes	3	4	Not Available	Confirm status and label container. Provide current SDS in a readily accessible location
Detroit Diesel Power Cool	Engine coolant	Electrical Switch Room, Adjacent Sprinkler Pump Room	20L x 2	40L	Yes	9	3	Not Available	Provide current SDS in a readily accessible location
Southern External Loading Area									
LPG	Fuel	Southern External Loading Area	~36kg x 3	~108kg	Yes	2.1	N/A	Not Available	Provide current SDS in a readily accessible location