

# HAZARDOUS CHEMICALS REGISTER

## Instructions

Complete, keep and maintain this *Hazardous Chemicals Register* for all existing and new chemicals used by staff. This register should be readily accessible by all staff and contractors who use or who may be affected or exposed to any of the hazardous chemicals listed herein.

All hazardous chemicals must have a current safety data sheet (SDS) and an accompanying risk assessment that is no more than five years old. The SDS must state whether the product is hazardous and, in case of dangerous goods, provide the proper shipping name, class label, subsidiary risk, and packing group details. Copies of the SDSs must be attached to this register.

<b>Site</b>		8 Chifley Square, Sydney NSW 2000			
<b>Date of Register</b>		8 <sup>th</sup> September 2025. Inspected on 20 <sup>th</sup> August 2025			
<b>Assessor</b>	<b>Name</b>	Phoebe Quessy	<b>Position Title</b>	Senior WHS Consultant	
	<b>Company</b>	Tetra Tech Coffey	<b>Client Contact Name</b>	Ernesto Capulong	

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
<b>Level 33 Cooling Tower Area</b>									
HydroChem Hydro 428	Corrosion and scale inhibitor	Level 33 Cooling Tower Area, dosing pot	15L x 1	15L	Yes	-	-	April 2026	-
Hydrochem Hydro 375	Water Treatment	Level 33 Cooling Tower Area, dosing pot	15kg x 1	15kg	Yes	5.1	2	June 2026	-

# HAZARDOUS CHEMICALS REGISTER



Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Hydrochem Hydro 2555	Water Treatment	Level 33 Cooling Tower Area	50L x 1	50L	Yes	8	2	<b>Not Available</b>	Provide current SDS in a readily accessible location. Remove incorrect label from secondary containment.
Hydrochem Hydro 360	Water Treatment	Level 33 Cooling Tower Area	15L x 1	15L	Yes	8	3	Mar 2026	Remove incorrect label from secondary containment.
Hydrochem Hydro 348	Water Treatment	Level 33 Cooling Tower Area	1L x 1	1L	No	-	-	Not Available	-
Hydrochem Hydro 260	Water Treatment	Level 33 Cooling Tower Area	50L x 1	50L	Yes	8	3	<b>Not Available</b>	Provide current SDS in a readily accessible location. Remove incorrect label from secondary containment.
<b>Level 33 Comms Room</b>									
12V Batteries	Battery	Level 33 Comms Room	20 units	20 units	Yes	8	N/A	<b>Not Available</b>	Provide current SDS in a readily accessible location
<b>Level 32 Generator Room</b>									

# HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
12V Batteries	Battery	Level 32 Generator Room	8 units	8 units	Yes	8	N/A	<b>Not Available</b>	Provide current SDS in a readily accessible location
Diesel	Fuel	Level 32 Generator Room	1,000L x 1	1,000L	Yes	3	4	<b>June 2024</b>	Replace expired SDS with current version
Elite Chloroclean	Cleaner	Level 32 Generator Room	20L x 1	20L	Yes	8	2	<b>Not Available</b>	Provide current SDS in a readily accessible location. Store within secondary containment
Elite Graffiti Remover	Cleaner	Level 32 Generator Room	5L x 1	5L	Yes	3	2	<b>Not Available</b>	Provide current SDS in a readily accessible location. Store within secondary containment
Whitely Mr Steel	Cleaner	Level 32 Generator Room	5L x 1	5L	No	-	-	Not Available	-
<b>Level 32 Trigen Room</b>									

# HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Oil	Oil	Level 32 Trigen Room	~1,000L x 1	~1,000L	No	-	-	Not Available	-
Unlabelled container	Water Treatment	Level 32 Trigen Room, dosing pot	15L x 1	15L	Unknown	Unknown	Unknown	<b>Not Available</b>	Label and provide current SDS in a readily accessible location
<b>Level 31 Chiller Room</b>									
R134a	Refrigerant	Level 22 Chiller Room, Chiller 1	398kg x 1	1,296kg	Yes	2.2	N/A	<b>Not Available</b>	Provide current SDS in a readily accessible location
		Level 22 Chiller Room, Chiller 2	398kg x 1						
		Level 22 Chiller Room, spare tank	500kg x 1						
<b>Level 30 Plant Room</b>									
HydroChem Hydro 428	Corrosion and scale inhibitor	Level 30 Plant Room, dosing pot	15L x 1	15L	Yes	-	-	<b>Not Available</b>	Provide current SDS in a readily accessible location
<b>Level 20 Cleaners Room</b>									
Envirocare	Cleaner	Level 20 Cleaners room	10kg x 1	10kg	Yes	-	-	<b>Not Available</b>	Provide current SDS in a readily accessible location
<b>Level 20 Plant Room</b>									

# HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Kincrome Hi Temp Bearing Grease	Grease	Level 20 Plant Room, on work bench	450g x 2	0.9kg	Yes	-	-	<b>Not Available</b>	Provide current SDS in a readily accessible location
Dulux Metal Sheild Epoxy Enamel	Paint	Level 20 Plant Room, on work bench	4L x 1	4L	Yes	3	3	<b>Not Available</b>	Provide current SDS in a readily accessible location. Segregate from Class 2.1 Aerosols.
Dulux Metal Sheild Epoxy Enamel	Spray Paint	Level 20 Plant Room, on work bench	300g x 2	0.6kg	Yes	2.1	N/A	<b>Not Available</b>	Provide current SDS in a readily accessible location. Segregate from Class 3 Chemicals.
Biz Line Silicone Roof and Gutter	Silicone	Level 20 Plant Room, on work bench	300mL x 1	0.3L	Yes	-	-	<b>Not Available</b>	Provide current SDS in a readily accessible location
Protek Green Type P PVC Cement	Glue	Level 20 Plant Room, on work bench	125mL x 1	0.125L	Yes	3	2	<b>Not Available</b>	Provide current SDS in a readily accessible location. Segregate from Class 2.1 Aerosols.
Protek Red Priming Fluid	Glue	Level 20 Plant Room, on work bench	125mL x 1	0.125L	Yes	3	2	<b>Not Available</b>	Provide current SDS in a readily accessible location. Segregate from Class 2.1 Aerosols.
WD-40	Aerosol	Level 20 Plant Room, on work bench	300g x 1	0.3kg	Yes	2.1	N/A	<b>Not Available</b>	Provide current SDS in a readily accessible location. Segregate from Class 3 Chemicals.
Diggers Paint Clean up	Cleaner	Level 20 Plant Room, on work bench	1L x 1	1L	Yes	-	-	<b>Not Available</b>	Provide current SDS in a readily accessible location
Dunlop AAC Block adhesive	Adhesive	Level 20 Plant Room, on work bench	15kg x 1	15kg	Yes	-	-	<b>Not Available</b>	Provide current SDS in a readily accessible location
Dunlop Tile Pointing	Tile Pointing	Level 20 Plant Room, on work bench	15kg x 1	15kg	Yes	-	-	<b>Not Available</b>	Provide current SDS in a readily accessible location

# HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
MR Fire Rated Duct Sealant	Sealant	Level 20 Plant Room, on work bench	4L x 1	4L	Yes	-	-	<b>Not Available</b>	Provide current SDS in a readily accessible location
<b>Level 19 Plant Room</b>									
HydroChem Hydro 428	Corrosion and scale inhibitor	Level 19 Plant Room, dosing pot	15L x 1	15L	Yes	-	-	<b>Not Available</b>	Provide current SDS in a readily accessible location
HydroChem Hydro 320	Water Treatment	Level 19 Plant Room, dosing pot	15L x 1	15L	No	-	-	Not Available	-
<b>Level 4 Plant Room</b>									
Sodium Hypochlorite	Water Treatment	Level 4 Plant Room	50L x 1	50L	Yes	8	3	<b>Nov 2015</b>	Replace expired SDS with current version
Liquid Chlorine	Water Treatment	Level 4 Plant Room	20L x 1	20L	Yes	8	3	<b>Not Available</b>	Provide current SDS in a readily accessible location
<b>Level 3 Plant Room</b>									
HydroChem Hydro 428	Corrosion and scale inhibitor	Level 3 Plant Room, dosing pot	15L x 1	15L	Yes	-	-	<b>Not Available</b>	Provide current SDS in a readily accessible location
<b>Level B1 Loading Dock</b>									
HydroChem Hydro 802	Water Treatment	Level B1 Loading Dock, dosing pot	15L x 1	15L	Yes	-	-	<b>Not Available</b>	Provide current SDS in a readily accessible location
<b>Level B1 Hydrant Pump Room</b>									

# HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
12V Batteries	Battery	Level B1 Hydrant Pump Room	2 units	2 units	Yes	8	N/A	<b>Not Available</b>	Provide current SDS in a readily accessible location
<b>Level B2 Cleaners Storeroom</b>									
Elite Red Flash Degreaser	Cleaner	Level B2 Cleaners Storeroom	20L x 3	60L	Yes	8	2	Jan 2026	Store at least 3m away from Class 3 chemicals.
Elite Clearclean Glass & Mirror Cleaner	Cleaner	Level B2 Cleaners Storeroom	20L x 2	40L	No	-	-	Jan 2026	-
Elite Eucalyptus Spray & Wipe	Cleaner	Level B2 Cleaners Storeroom	20L x 4	80L	No	-	-	Jan 2026	-
Elite Multiklean	Cleaner	Level B2 Cleaners Storeroom	20L x 2	40L	Yes	-	-	<b>Jan 2023</b>	Replace the expired SDS with current version
Elite Carpet Wiz	Cleaner	Level B2 Cleaners Storeroom	5L x 1	5L	No	-	-	Not Available	-
Amano Pioneer Eclipse Neutral All Purpose Cleaner	Cleaner	Level B2 Cleaners Storeroom	10L x 1	10L	No	-	-	April 2026	-
Whiteley Tile Plus	Cleaner	Level B2 Cleaners Storeroom	5L x 4	20L	Yes	8	2	<b>Not Available</b>	Provide current SDS in a readily accessible location. Store at least 3m away from Class 3 chemicals.

## HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Elite White Oil	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	No	-	-	Not Available	-
Whitley Mr Steel	Cleaner	Level B2 Cleaners Storeroom	5L x 4	20L	No	-	-	Aug 2026	-
Solution Glass Mirror and Chrome	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	No	-	-	Not Available	-
B24 Saniform	Cleaner	Level B2 Cleaners Storeroom	5L x 2	10L	Yes	3	3	<b>Not Available</b>	Provide current SDS in a readily accessible location. Store at least 3m away from Class 8 chemicals.
Agar Flash Dry	Cleaner	Level B2 Cleaners Storeroom	5L x 2	10L	Yes	-	-	<b>Not Available</b>	Provide current SDS in a readily accessible location
Elite Ultra Fresh	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	No	-	-	Jan 2023	-
Elite Disinfectant Lemon	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	No	-	-	Jan 2026	-
Smart San	Cleaner	Level B2 Cleaners Storeroom	5L x 1	5L	Yes	3	2	<b>Not Available</b>	Provide current SDS in a readily accessible location. Store at least 3m away from Class 8 chemicals.
Elite Graffiti Remover	Cleaner	Level B2 Cleaners Storeroom	5L x 1 1L x 1	6L	Yes	3	2	Jul 2029	Store at least 3m away from Class 8 chemicals.

# HAZARDOUS CHEMICALS REGISTER



Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Zexa Sure Sheild	Cleaner	Level B2 Cleaners Storeroom	5L x 1	5L	No	-	-	Not Available	-
<b>Level B2 Diesel Tank Room</b>									
Diesel	Fuel	Level B2 Diesel Tank Room	11,000L x 1	11,000L	Yes	3	4	<b>Not Available</b>	Provide current SDS in a readily accessible location
<b>Level B3 Sprinkler Pump Room</b>									
12V Batteries	Battery	Level 22 Generator Room	2 units	2 units	Yes	8	N/A	<b>Not Available</b>	Provide current SDS in a readily accessible location