

# HAZARDOUS CHEMICALS REGISTER

## Instructions

Complete, keep and maintain this *Hazardous Chemicals Register* for all existing and new chemicals used by staff. This register should be readily accessible by all staff and contractors who use or who may be affected or exposed to any of the hazardous chemicals listed herein.

All hazardous chemicals must have a current safety data sheet (SDS) and an accompanying risk assessment that is no more than five years old. The SDS must state whether the product is hazardous and, in case of dangerous goods, provide the proper shipping name, class label, subsidiary risk, and packing group details. Copies of the SDSs must be attached to this register.

Site		8 Chifley Square, Sydney NSW 2000			
Date of Register		6 <sup>th</sup> August 2024. Inspected on 1 <sup>st</sup> August 2024			
Assessor	Name	Ben McCann	Position Title	Senior Associate – Property Risk	
	Company	Tetra Tech Coffey	Client Contact Name	Ali Kamandi	

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Level 33 Cooling Tower Area									
HydroChem Hydro 428	Corrosion and scale inhibitor	Level 33 Cooling Tower Area, dosing pot	1 x 15L	15L	Yes	-	-	April 2026	-
Hydrochem Hydro 375	Water Treatment	Level 33 Cooling Tower Area, dosing pot	15kg x 1	15kg	Yes	5.1	2	June 2026	-

## HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Hydrochem Hydro 2555	Water Treatment	Level 33 Cooling Tower Area	50L x 1	50L	Yes	8	2	<b>Not Available</b>	Provide current SDS in a readily accessible location
Hydrochem Hydro 360	Water Treatment	Level 33 Cooling Tower Area	15L x 1	15L	Yes	8	3	<b>Not Available</b>	Provide current SDS in a readily accessible location
Hydrochem Hydro 260	Water Treatment	Level 33 Cooling Tower Area	50L x 1	50L	Yes	8	3	April 2026	-
<b>Level 33 Comms Room</b>									
12V Batteries	Battery	Level 33 Comms Room	20 units	20 units	Yes	8	N/A	<b>Not Available</b>	Provide current SDS in a readily accessible location
<b>Level 32 Generator Room</b>									
12V Batteries	Battery	Level 32 Generator Room	4 units	4 units	Yes	8	N/A	<b>Not Available</b>	Provide current SDS in a readily accessible location

## HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Diesel	Fuel	Level 32 Generator Room	1,000L x 1	1,000L	Yes	3	4	<b>June 2024</b>	Replace expired SDS with current version
Two Good Co. Shampoo	Cleaner	Level 32 Generator Room	5L x 15	75L	Unknown	Unknown	Unknown	<b>Not Available</b>	Provide current SDS in a readily accessible location
Two Good Co. Conditioner	Cleaner	Level 32 Generator Room	5L x 15	75L	Unknown	Unknown	Unknown	<b>Not Available</b>	Provide current SDS in a readily accessible location
Two Good Co. Body Wash	Cleaner	Level 32 Generator Room	5L x 15	75L	Unknown	Unknown	Unknown	<b>Not Available</b>	Provide current SDS in a readily accessible location
Zexa Sure Shield Hand & Body Wash	Cleaner	Level 32 Generator Room	5L x 3	15L	-	-	-	Not Available	-

## HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Clean Plus Vira San	Cleaner	Level 32 Generator Room	5L x 3	15L	Yes	-	-	Not Available	Provide current SDS in a readily accessible location
Level 32 Trigen Room									
Oil	Oil	Level 32 Trigen Room	~1,000L x 1	~1,000L	-	-	-	Not Available	-
Unlabelled container	Water Treatment	Level 32 Trigen Room, dosing pot	15L x 1	15L	Unknown	Unknown	Unknown	Not Available	Label and provide current SDS in a readily accessible location
Level 31 Chiller Room									
R134a	Refrigerant	Level 22 Chiller Room, Chiller 1	398kg x 1	1,296kg	Yes	2.2	N/A	Not Available	Provide current SDS in a readily accessible location
		Level 22 Chiller Room, Chiller 2	398kg x 1						
		Level 22 Chiller Room, spare tank	500kg x 1						
Level 30 Plant Room									
HydroChem Hydro 428	Corrosion and scale inhibitor	Level 30 Plant Room, dosing pot	1 x 15L	15L	Yes	-	-	Not Available	Provide current SDS in a readily accessible location

## HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Level 30 Cleaners Storeroom									
Elite Clearclean Glass & Mirror Cleaner	Cleaner	Level 30 Cleaners Storeroom	20L x 1	20L	-	-	-	Not Available	-
Elite Disinfectant Lemon	Cleaner	Level 30 Cleaners Storeroom	20L x 1	20L	-	-	-	Not Available	-
Elite Ultra Fresh	Cleaner	Level 30 Cleaners Storeroom	20L x 1	20L	-	-	-	Not Available	-
Enviro Chemicals White Oil	Cleaner	Level 30 Cleaners Storeroom	5L x 1	5L	-	-	-	Not Available	-
Zexa Sure Shield Hand & Body Wash	Cleaner	Level 30 Cleaners Storeroom	5L x 1	5L	-	-	-	Not Available	-
Whiteley Mr Steel	Water Treatment	Level 30 Cleaners Storeroom	5L x 3	15L	-	-	-	Not Available	-
Level 19 Plant Room									
HydroChem Hydro 428	Corrosion and scale inhibitor	Level 19 Plant Room, dosing pot	15L x 1	15L	Yes	-	-	Not Available	Provide current SDS in a readily accessible location
HydroChem Hydro 320	Water Treatment	Level 19 Plant Room, dosing pot	15L x 1	15L	-	-	-	Not Available	-

## HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Level 4 Plant Room									
Sodium Hypochlorite	Water Treatment	Level 4 Plant Room	50L x 1	50L	Yes	8	3	Nov 2015	Replace expired SDS with current version
Level 3 Plant Room									
HydroChem Hydro 428	Corrosion and scale inhibitor	Level 3 Plant Room, dosing pot	15L x 1	15L	Yes	-	-	Not Available	Provide current SDS in a readily accessible location
Level B1 Loading Dock									
HydroChem Hydro 802	Water Treatment	Level B1 Loading Dock, dosing pot	15L x 1	15L	Yes	-	-	Not Available	Provide current SDS in a readily accessible location
Level B1 Hydrant Pump Room									
12V Batteries	Battery	Level B1 Hydrant Pump Room	2 units	2 units	Yes	8	N/A	Not Available	Provide current SDS in a readily accessible location
Level B2 Cleaners Storeroom									
Elite Red Flash Detergent	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	Yes	8	2	Jan 2026	-
Elite Clearclean Glass & Mirror Cleaner	Cleaner	Level B2 Cleaners Storeroom	20L x 2	40L	-	-	-	Jan 2026	-

## HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Elite Chloroclean	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	Yes	8	2	<b>Not Available</b>	Provide current SDS in a readily accessible location
Elite King Bleach	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	Yes	8	3	<b>Jan 2023</b>	Replace expired SDS with current version
Elite Uriclean	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	Yes	-	-	Jan 2026	-
Elite Eucalyptus Spray & Wipe	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	-	-	-	Jan 2026	-
Elite Multiklean	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	Yes	-	-	<b>Jan 2023</b>	Replace expired SDS with current version
Elite Ultra Fresh	Cleaner	Level B2 Cleaners Storeroom	20L x 5	100L	-	-	-	Jan 2023	-
Elite Carpet Wiz	Cleaner	Level B2 Cleaners Storeroom	5L x 1	5L	-	-	-	Not Available	-
Amano Pioneer Eclipse Neutral All Purpose Cleaner	Cleaner	Level B2 Cleaners Storeroom	10L x 2	20L	-	-	-	April 2026	-
Whiteley Tile Plus	Cleaner	Level B2 Cleaners Storeroom	5L x 8	40L	Yes	8	2	<b>Not Available</b>	Provide current SDS in a readily accessible location

## HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Elite White Oil	Cleaner	Level B2 Cleaners Storeroom	20L x 1	20L	-	-	-	Not Available	-
<b>Level B2 Diesel Tank Room</b>									
Diesel	Fuel	Level B2 Diesel Tank Room	11,000L x 1	11,000L	Yes	3	4	<b>June 2024</b>	Replace expired SDS with current version
<b>Level B3 Sprinkler Pump Room</b>									
12V Batteries	Battery	Level 22 Generator Room	2 units	2 units	Yes	8	N/A	<b>Not Available</b>	Provide current SDS in a readily accessible location