

# HAZARDOUS CHEMICALS REGISTER

## Instructions

Complete, keep and maintain this *Hazardous Chemicals Register* for all existing and new chemicals used by staff. This register should be readily accessible by all staff and contractors who use or who may be affected or exposed to any of the hazardous chemicals listed herein.

All hazardous chemicals must have a current safety data sheet (SDS) and an accompanying risk assessment that is no more than five years old. The SDS must state whether the product is hazardous and, in case of dangerous goods, provide the proper shipping name, class label, subsidiary risk, and packing group details. Copies of the SDSs must be attached to this register.

<b>Site</b>		80 Pacific Highway, North Sydney, NSW			
<b>Date of Register</b>		29 <sup>th</sup> September 2025. Inspected on 19 <sup>th</sup> August 2025.			
<b>Assessor</b>	<b>Name</b>	Ben McCann	<b>Position Title</b>	WHS Practice Leader - NSW	
	<b>Company</b>	Tetra Tech Coffey	<b>Client Contact Name</b>	Andrew Cartwright	

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
<b>Level 15, Cooling Tower Room</b>									
HydroChem Hydro 360	Corrosion and scale inhibitor	Level 15, Cooling Tower Room	1 x 15L	15L	Yes	8	3	<b>Not Available</b>	Provide current SDS in a readily accessible location
HydroChem Hydro 256	Water treatment biocide	Level 15, Cooling Tower Room	2 x 15L	30L	Yes	8	3	<b>Not Available</b>	Provide current SDS in a readily accessible location
HydroChem Hydro 375	Water treatment biocide	Level 15, Cooling Tower Room, in erosion feeder	1 x ~15kg	~15kg	Yes	5.1 (8)	2	<b>Not Available</b>	Provide current SDS in a readily accessible location
HydroChem Hydro 407X	Corrosion and scale inhibitor	Level 15, Cooling Tower Room	1 x 15L	15L	-	-	-	Not Available	-

# HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Unlabelled container	Unknown	Level 15, Cooling Tower Room, in erosion feeder	1 x 15kg	15kg	Unknown	Unknown	Unknown	<b>Not Available</b>	Label container or remove from site. Provide current SDS in a readily accessible location
<b>Level 15, Chiller Room</b>									
R-1234ze	Refrigerant	Level 15, Chiller Room, within Chillers	2 x 347kg	694kg	Yes	2.2	N/A	<b>Not Available</b>	Provide current SDS in a readily accessible location
HydroChem Hydro 428	Corrosion and scale inhibitor	Level 15, Chiller Room, in dosing pot	1 x 15L	15L	Yes	-	-	<b>Not Available</b>	Provide current SDS in a readily accessible location
<b>Level 15, Generator Room</b>									
Diesel	Fuel	Level 15, Generator Room	1 x ~1,000L	~1,000L	Yes	3	4	June 2026	-
Odyssey PC1700 12V Batteries	Batteries	Level 15, Generator Room	4 x units	4 x units	Yes	8	N/A	<b>Not Available</b>	Provide current SDS in a readily accessible location
<b>Level 15, Boiler Room</b>									
HydroChem Hydro 428	Closed circuit corrosion inhibitor	Level 15, Boiler Room	1 x 15L	30L	Yes	-	-	<b>Not Available</b>	Store within appropriate secondary containment. Provide current SDS in a readily accessible location
		Level 15, Boiler Room, in dosing pot	1 x 15L						Provide current SDS in a readily accessible location
<b>Level B1, Distribution Frame Room</b>									

# HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Leoch International Front Access Gel 12V Batteries	Batteries	Level B1, MSB Room	16 x units	16 x units	Yes	8	N/A	<b>Not Available</b>	Provide current SDS in a readily accessible location
<b>Level B2, Cleaners Store Room</b>									
Enviro Chemicals Ultra Fresh	Cleaner	Level B2, Cleaners Store Room	20L x 1	20L	-	-	-	Jan 2028	-
Enviro Chemicals Multiklean	Cleaner	Level B2, Cleaners Store Room	20L x 1	20L	Yes	-	-	Jan 2028	-
Elite Clearclean Glass & Mirror Cleaner	Cleaner	Level B2, Cleaners Store Room	20L x 1	20L	-	-	-	<b>Not Available</b>	Provide current SDS in a readily accessible location
Elite Eucalyptus Spray & Wipe	Cleaner	Level B2, Cleaners Store Room	20L x 4	80L	-	-	-	Jan 2031	-
Elite King Bleach	Cleaner	Level B2, Cleaners Store Room	20L x 1	20L	Yes	8	3	Jan 2028	-
Elite Chloroclean	Cleaner	Level B2, Cleaners Store Room	20L x 1	20L	Yes	8	2	Jan 2030	-

# HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Elite Disinfectant Lemon	Cleaner	Level B2, Cleaners Store Room	20L x 1	20L	-	-	-	Jan 2031	-
Elite Red Flash Degreaser	Cleaner	Level B2, Cleaners Store Room	20L x 2	40L	Yes	8	3	Jan 2030	-
Whiteley Mr Steel	Cleaner	Level B2, Cleaners Store Room	5L x 3	15L	-	-	-	Not Available	-
Whiteley Tile Plus	Cleaner	Level B2, Cleaners Store Room	5L x 3	15L	Yes	8	2	Jan 2030	-
Elite Solution	Cleaner	Level B2, Cleaners Store Room	20L x 1	20L	Unknown	Unknown	Unknown	<b>Not Available</b>	Provide current SDS in a readily accessible location
Cleera Liquid Hand Wash	Cleaner	Level B2, Cleaners Store Room	5L x 2	10L	Yes	-	-	Jan 2030	-
Star Hygiene Sanispray D25	Cleaner	Level B2, Cleaners Store Room	5L x 4	20L	Yes	3	2	<b>Not Available</b>	Provide current SDS in a readily accessible location

# HAZARDOUS CHEMICALS REGISTER



Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
<b>Level B4, Fire Pump Room</b>									
Diesel	Fuel	Level B4, Fire Pump Room	1 x ~100L 2 x 20L	~140L	Yes	3	4	June 2028	-
Aus Cell 12V Batteries	Batteries	Level B4, Fire Pump Room	3 x units	3 x units	Yes	8	N/A	June 2028	-
<b>Level B4, Diesel Tank Room</b>									
Diesel	Fuel	Level B4, Diesel Tank Room	1 x ~12,000L	~12,000L	Yes	3	4	June 2026	-
Hi Tec Oils PG-XL 50	Engine Coolant	Level B4, Diesel Tank Room	1 x 20L	20L	-	-	-	June 2026	-