

HAZARDOUS CHEMICALS REGISTER



Instructions

Complete, keep and maintain this *Hazardous Chemicals Register* for all existing and new chemicals used by staff. This register should be readily accessible by all staff and contractors who use or who may be affected or exposed to any of the hazardous chemicals listed herein.

All hazardous chemicals must have a current safety data sheet (SDS) and an accompanying risk assessment that is no more than five years old. The SDS must state whether the product is hazardous and, in case of dangerous goods, provide the proper shipping name, class label, subsidiary risk, and packing group details. Copies of the SDSs must be attached to this register.

Site		Hoxton Park Distribution Centre, 40 Blackbird Close, Hoxton Park NSW			
Date of Register		21 st January 2025. Inspected on 11 th December 2024			
Assessor	Name	Ben McCann	Position Title	Senior Associate – Property Risk	
	Company	Tetra Tech Coffey	Client Contact Name	Jino Velasco	

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Southern Fire Pump Room									
Diesel	Fuel	Southern Fire Pump Room	1,500L x 1 1,000L x 1	2,500L	Yes	3	4	Not Available	Provide current SDS in a readily accessible location
12V Batteries	Battery	Southern Fire Pump Room	8 units	8 units	Yes	8	N/A	Not Available	Provide current SDS in a readily accessible location

HAZARDOUS CHEMICALS REGISTER



Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity		Class	Category		
Northern Fire Pump Room									
Diesel	Fuel	Northern Fire Pump Room	1,500L x 2	3,000L	Yes	3	4	Not Available	Provide current SDS in a readily accessible location
12V Batteries	Battery	Northern Fire Pump Room	6 units	6 units	Yes	8	N/A	Not Available	Provide current SDS in a readily accessible location