

HAZARDOUS CHEMICALS REGISTER

Instructions

Complete, keep and maintain this *Hazardous Chemicals Register* for all existing and new chemicals used by staff. This register should be readily accessible by all staff and contractors who use or who may be affected or exposed to any of the hazardous chemicals listed herein.

All hazardous chemicals must have a current safety data sheet (SDS) and an accompanying risk assessment that is no more than five years old. The SDS must state whether the product is hazardous and, in case of dangerous goods, provide the proper shipping name, class label, subsidiary risk, and packing group details. Copies of the SDSs must be attached to this register.

Site	669 Bourke Street, Docklands, Victoria				
Date of Register	22 nd August 2025 (based on 7 th July 2025 inspection)				
Assessor	Name	Phoebe Quessy		Position Title	Senior WHS Consultant
	Company	Tetra Tech Coffey		Client Contact Name	Darren Hynes

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity (L or Kg)		Class	Packing Group		
Level 3, Diesel Tank Room									
Diesel	Fuel	Level 3, Diesel Tank Room	2 x 2,500L 1 x 2,000L	7,000L	Yes	C1	N/A	Dec 2025	-
Level 3, Generator Room									
CAT 12V Batteries	Battery	Level 3, Generator Room	4 x units	4 x units	Yes	8	N/A	Not Available	Provide current SDS in a readily accessible location
Diesel	Fuel	Level 3, Generator Room	2 x 200L	400L	Yes	C1	N/A	Not Available	Provide current SDS in a readily accessible location

HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity (L or Kg)		Class	Packing Group		
Caterpillar CAT DEO 15W-40 Diesel Engine Oil	Engine oil	Level 3, Generator Room	1 x 20L	20L	-	-	-	Not Available	Provide current SDS in a readily accessible location
Co-Gen Generator Room									
12V Batteries	Battery	Level 3, Co-Gen Generator Room	2 x units	2 x units	Yes	8	N/A	Not Available	Provide current SDS in a readily accessible location
Diesel	Fuel	Level 3, Co-Gen Generator Room	1 x 400L	400L	Yes	C1	N/A	Not Available	Provide current SDS in a readily accessible location
Level 3, Chiller Plant Room									
R-134a	Refrigerant	Level 3, Chiller Plant Room, chillers	2 x 295Kg 1 x 808Kg	1,398kg	Yes	2.2	N/A	Not Available	Provide current SDS in a readily accessible location
Unknown	Unknown	Level 3, Chiller Plant Room	1 x 5L	5L	Unknown	Unknown	Unknown	Not Available	Label chemical appropriately or remove from site. Provide current SDS in a readily accessible location
Hydro 428	Water treatment	Level 3, Chiller Plant Room	2 x 15L	45L	Yes	-	-	Not Available	Provide current SDS in a readily accessible location
		Level 3, Chiller Plant Room, dosing pot	1 x 15L						
Level 12, Cooling Tower Area									
Hydro 360	Water treatment	Level 12, Cooling Tower Area, AGL Tower	1 x 15L	30L	Yes	8	III	Mar 2026	-

HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity (L or Kg)		Class	Packing Group		
Hydro 256	Water treatment	Level 12, Cooling Tower Area, base building area	1 x 15L						
		Level 12, Cooling Tower Area, AGL Tower	1 x 15L	45L	Yes	8	III	Feb 2028	-
		Level 12, Cooling Tower Area, base building area	2 x 15L						
Hydro 260	Water treatment	Level 12, Cooling Tower Area, AGL Tower	1 x 15L	15L	Yes	8	III	Apr 2026	-
Hydro 375	Water treatment	Level 12, Cooling Tower Area, base building area	1 x 15Kg	30kg	Yes	5.1 (8)	II	Jun 2026	-
		Level 12, Cooling Tower Area, base building area, erosion pot	1 x 15Kg						
Hydro 348	Water treatment	Level 12, Cooling Tower Area, base building area	1 x 5L	5L	-	-	-	July 2025	-
Hydro 408	Water treatment	Level 12, Cooling Tower Area, base building area	1 x 15L	15L	-	-	-	Not Available	Provide current SDS in a readily accessible location
Hydro 326	Water treatment	Level 12, Cooling Tower Area, base building area	1 x 4kg	4kg	-	-	-	Oct 2026	-
Hydro 5801	Water treatment	Level 12, Cooling Tower Area, base building area	2 x 5L	10L	Yes	8	III	Oct 2026	-
Hydro 440	Water treatment	Level 12, Cooling Tower Area, base building area	1 x 4kg	4kg	Yes	-	-	Not Available	Provide current SDS in a readily accessible location

HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity (L or Kg)		Class	Packing Group		
Level 12, Plant Room									
LPG	Fuel	Level 12, Plant Room	7 x 21kg	147kg	Yes	2.1	N/A	Not Available	Provide current SDS in a readily accessible location
Hydro 408X	Water Treatment	Level 12, CT area, base building	1 x 15L	15L	-	-	-	Not Available	Provide current SDS in a readily accessible location
Hydro 428	Water treatment	Level 12, Plant Room, dosing pots	3 x 15L	45L	Yes	-	-	Dec 2026	-