

HAZARDOUS CHEMICALS REGISTER

Instructions

Complete, keep and maintain this *Hazardous Chemicals Register* for all existing and new chemicals used by staff. This register should be readily accessible by all staff and contractors who use or who may be affected or exposed to any of the hazardous chemicals listed herein.

All hazardous chemicals must have a current safety data sheet (SDS) and an accompanying risk assessment that is no more than five years old. The SDS must state whether the product is hazardous and, in case of dangerous goods, provide the proper shipping name, class label, subsidiary risk, and packing group details. Copies of the SDSs must be attached to this register.

Site		7 Spencer Street, Docklands 3008 Victoria			
Date of Register		21 st July 2026 (based on inspection on 4 June 2026)			
Assessor	Name	Greig McKellar	PositionTitle	WHS Practice Leader – VIC/SA/TAS	
	Company	Tetra Tech Coffey	Client Contact Name	Stephen Bushell	

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity (L or Kg)		Class	Packing Group		
Roof Cooling Towers									
Hydrochem Hydro 375	Water Treatment	Roof Cooling Towers	1 x 15Kg	15Kg	Yes	5.1	III	Nov 2030	Store at least 3m away from Class 8 chemicals.
Hydrochem Hydro 326	Alkaline	Roof Cooling Towers	1 x 4Kg	4Kg	-	-	-	Dec 2030	-
Hydrochem Hydro 257	Cooling Water Biocide	Roof Cooling Towers	2 x 15L	30L	Yes	8	III	March 2031	Store at least 3m away from Class 5.1 chemicals.
Hydrochem Hydro 408X	Corrosion and Scale Inhibitor	Roof Cooling Towers	2 x 15L	30L	-	-	-	Oct 2030	-
Hydrochem Hydro 371	Water Treatment	Roof Cooling Towers	1 x 1L	1L	-	-	-	Jan 2031	-

HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity (L or Kg)		Class	Packing Group		
Hydrochem Hydro 5801	Corrosion and Scale Inhibitor	Roof Cooling Towers	1 x 5L	5L	Yes	8	III	Oct 2030	Store at least 3m away from Class 5.1 chemicals.
Level 21 Generator Room									
Diesel	Fuel	Generator Room – Internal DRAC	1 x 1,000L 1 x 500L	1,500L	Yes	C1	N/A	Not Available	Provide current SDS in a readily accessible location
Delkor 12v Batteries Commercial	Power	Generator Room	2 x Units	2 Units	Yes	8	N/A	Not Available	Provide current SDS in a readily accessible location
Level 11 Electrical Riser Room									
12v Batteries Commercial	Power	Electrical Riser Room Control Panel	2 x Units	2 Units	Yes	8	N/A	Not Available	Provide current SDS in a readily accessible location
Level 10 Electrical Riser Room									
12v Batteries Commercial	Power	Electrical Riser Room Control Panel	2 x Units	2 Units	Yes	8	N/A	Not Available	Provide current SDS in a readily accessible location
Level 1 Fire Pump Room									
SPPTL 12v Batteries Commercial	Power	Fire Pump Room	2 x Units	2 Units	Yes	8	N/A	Not Available	Provide current SDS in a readily accessible location
Ground Floor Refuse and Cleaners Room									

HAZARDOUS CHEMICALS REGISTER

Product Name	Purpose	Location	Quantity		Hazardous Substance	Dangerous Goods		SDS Expiry	Actions/Comments
			Number of Containers	Max Quantity (L or Kg)		Class	Packing Group		
Agar All Purpose Cleaner	Cleaning	Ground Floor Refuse and Cleaners Room	5 x 5L 4 x 0.5L	27L	Yes	8	III	April 2030	-
Agar Disinfectant	Cleaning	Ground Floor Refuse and Cleaners Room	3 x 5L 7 x 0.5L	18.5L	Yes	8	III	May 2031	-
Agar Bellevue	Cleaning	Ground Floor Refuse and Cleaners Room	3 x 5L 22 x 0.5L	36L	Yes	8	III	April 2031	-
Agar Shower Star	Cleaning	Ground Floor Refuse and Cleaners Room	2 x 5L	10L	Yes	8	III	Not Available	Provide current SDS in a readily accessible location
Agar Steel Shine	Cleaning	Ground Floor Refuse and Cleaners Room	4 x 1L	4L	Yes	8	III	March 2031	-
Agar Fresco	Cleaning	Ground Floor Refuse and Cleaners Room	4 x 5L	20L	Yes	8	III	May 2031	-
Ground Floor Fire Control Room									
12v Batteries Commercial	Power	Fire Control Room – Fire Control Panel	2 x Units	2 Units	Yes	8	N/A	Not Available	Provide current SDS in a readily accessible location
12v Batteries Commercial	Power	Fire Control Room – EWIS Panel	2 x Units	2 Units	Yes	8	N/A	Not Available	Provide current SDS in a readily accessible location
Ground Floor Loading Dock									
Diesel	Fuel	Loading Dock	1 x 19,000L	19,000L	Yes	C1	N/A	Not Available	Provide current SDS in a readily accessible location